



SPORTS FIELD LIGHTING – CERTIFICATE OF COMPLIANCE

The lighting of all playing fields must comply with Australian Standard AS 2560.2.3 – 2002 Sports Lighting Part 2.3 Lighting for Football (all Codes) for training and competition matches.

Field lighting must be tested annually, and a signed Certificate of Compliance submitted to the Rugby League Brisbane office by **12 NOON 28 FEBRUARY 2022 or before any trial matches.**

NOTE: Audit must be lodged prior to Rugby League Brisbane approval for all evening matches.

Night matches will not be allocated until field lighting has been tested and certified by an accredited sports lighting engineer who has been endorsed by Rugby League Brisbane.

The results of the lighting test together with the details and signature of the person conducting the test are to be recorded on this form.

The Standard requires, at an amateur level:

- a. For ball and physical training, a minimum average maintained horizontal illuminance (Emh) of 50 with a minimum horizontal uniformity of 0.3; and
- b. For club competition and match practice a minimum average maintained horizontal illuminance (Emh) of 100 with a minimum horizontal uniformity of 0.5.

The Local League reserves the right to independently test fields at any time during a season to ensure ongoing compliance with the Standard.

Club Name: _____

Date of Audit: / /

Ground/Location: _____

Playing Field No: _____

Luminance Level: _____

Uniformity Min/Ave: _____

Test Equipment Used: _____

Date of Last Calibration: / /

Date Next Calibration Due: / /

The above playing field complies with the above Australian Standard.

Test Performed By: _____

(Name)

(Signature)

Company Name: _____ Qualification: _____